

COLUMBIA POWER TECHNOLOGIES

power from the next wave

Attachment 3
Pre-Project TAEP calculations

Title	Pre-Project TAEP calculations
Document No.	
Version	1.1
Authored	P Lenec-Bluhm
Reviewed	K. Rhinefrank
Approved	K. Rhinefrank

Version	Date	Summary
1.1	16 November, 2016	

TABLE OF CONTENTS

1	INTRODUCTION	1
2	PERFORMANCE AND LOSS MATRICES	1
3	AEP CALCULATIONS	5
3.1	Summary	5
3.2	DOE Reference (NDBC 46212)	7
3.3	Hawaii (WETS B).....	8
3.4	Oregon (NDBC 46050)	9
3.5	Ireland (AMETS A)	10

TABLE OF FIGURES

Figure 1	– Performance matrix of mechanical power extracted.....	2
Figure 2	– Performance matrix of electrical power captured.....	2
Figure 3	– Matrix of PTO losses.	3
Figure 4	– Matrix of generator losses.	3
Figure 5	– Matrix of ancillary losses.	4
Figure 6	– Fore float configuration depicted in matrix format.....	4
Figure 7	– TAEP at four sites of interest.	6

TABLE OF TABLES

Table 1	– Mean annual power at four sites of interest.....	5
Table 2	– TAEP at four sites of interest.....	5
Table 3	– Mean annual power and losses for DOE reference site.....	7
Table 4	– Mean annual power and losses for Hawaii (WETS B).....	8
Table 5	– Mean annual power and losses for Oregon (NDBC 46050).....	9
Table 6	– Mean annual power and losses for Ireland (AMETS A).....	10

1 INTRODUCTION

Simulations and calculations are carried out according to ‘Energy Production Assessment for DOE LCOE and SPA Reporting’.

2 PERFORMANCE AND LOSS MATRICES

Performance matrices are depicted, with simulation conditions specified by the midpoint of each populated cell in the matrix. Mechanical power extracted (Figure 1) is calculated before any mechanical or electrical losses. Electrical power captured (Figure 2) is calculated as grid quality power, after all mechanical and electrical losses.

Losses are calculated as described in ‘Energy Production Assessment for DOE LCOE and SPA Reporting’. PTO losses (Figure 3) include mechanical losses from the main bearings, idler bearings, and seals. Generator losses (Figure 4) include mechanical losses from the novel rail bearing system and electrical losses from the generator. Ancillary losses (Figure 5) include losses from power electronics, hotel loads and transformer.

The sea states where the fore-in-aft configuration was modeled are depicted in matrix form in Figure 6.




Figure 1 – Performance matrix of mechanical power extracted.




Figure 2 – Performance matrix of electrical power captured.

The following contains proprietary information of Columbia Power Technologies, Inc. not for distribution.




Figure 3 – Matrix of PTO losses.




Figure 4 – Matrix of generator losses.




Figure 5 – Matrix of ancillary losses.




Figure 6 – Fore float configuration depicted in matrix format.

3 AEP CALCULATIONS

3.1 Summary

TAEP at various stages of power conversion chain are given below for four resources. Further details are given in the following sections for each site. Availability and transmission losses are accounted for in the main body of ‘MS13.1 EE-0006399 LCOE and SPA’.

Table 1 – Mean annual power at four sites of interest.

Site	Mean Power [kW]			
	Mech extracted	Mech into generator (pre rail bear)	Elec out of generator	Elec captured
DOE Reference (NDBC 46212)	106	98	71	62
Hawaii (WETS B)	94	87	62	54
Oregon (NDBC 46050)	129	120	88	78
Ireland (AMETS A)	183	169	127	114

Table 2 – TAEP at four sites of interest.

Site	Theoretical Annual Energy Production [MWh]			
	Mech extracted	Mech into generator (pre rail bearing)	Elec out of generator	Elec captured
DOE Reference (NDBC 46212)	926	862	622	547
Hawaii (WETS B)	822	767	546	476
Oregon (NDBC 46050)	1134	1053	771	685
Ireland (AMETS A)	1600	1482	1109	1000




Figure 7 – TAEP at four sites of interest.


3.2 DOE Reference (NDBC 46212)

Table 3 – Mean annual power and losses for DOE reference site.


Source data: L2228-N2673 and L2228-N2674

Working folder:Z:\Engineering\LandRAY\Design Files\0000 Design Conditions and Response\LCOE

Power Annual Power [kW]	CA (DOE ref)
Mechanical power extracted	105.7
Mechanical power into generator (before rail bearing losses)	98.4
Mechanical power into generator (after rail bearing losses)	93.1
Electrical power out of generator	71.0
Electrical power capture (used for TAEP calculation)	62.4



Losses [kW]	CA (DOE ref)
Fore primary bearing	0.3
Fore secondary bearing	1.1
Fore idler bearing	1.9
Fore seals	0.3
Fore rail bearing	2.9
Fore generator electrical	12.9
Aft primary bearing	0.4
Aft secondary bearing	0.9
Aft idler bearing	2.2
Aft seals	0.2
Aft rail bearing	2.4
Aft generator electrical	9.2
Power electronics	3.5
Hotel loads	2.9
Transformer	2.1



Losses by stage [kW]	CA (DOE ref)	Efficiency	Efficiency is with respect to...
PTO mechanical losses (prim/sec bearings + idler bearings + seals)	7.3	93%	Mech power extracted
Generator losses (rail + generator electrical)	27.4	72%	Mech power into gen (before rail losses)
Generator rail losses	5.3	95%	Mech power extracted
Generator electrical losses	22.1	76%	Mech power into gen (after rail losses)
Ancillary losses (PE + hotel + Transformer)	8.5	88%	Elec power out of generator


3.3 Hawaii (WETS B)

Table 4 – Mean annual power and losses for Hawaii (WETS B).


Source data: L2228-N2673 and L2228-N2674

Working folder:Z:\Engineering\LandRAY\Design Files\0000 Design Conditions and Response\LCOE

Power Annual Power [kW]	HI (WETS)
Mechanical power extracted	93.8
Mechanical power into generator (before rail bearing losses)	87.5
Mechanical power into generator (after rail bearing losses)	82.5
Electrical power out of generator	62.3
Electrical power capture (used for TAEP calculation)	54.3



Losses [kW]	HI (WETS)
Fore primary bearing	0.3
Fore secondary bearing	1.0
Fore idler bearing	1.6
Fore seals	0.3
Fore rail bearing	2.8
Fore generator electrical	12.2
Aft primary bearing	0.3
Aft secondary bearing	0.8
Aft idler bearing	1.8
Aft seals	0.2
Aft rail bearing	2.2
Aft generator electrical	8.0
Power electronics	3.1
Hotel loads	2.8
Transformer	2.0



Losses by stage [kW]	HI (WETS)	Efficiency	Efficiency is with respect to...
PTO mechanical losses (prim/sec bearings + idler bearings + seals)	6.3	93%	Mech power extracted
Generator losses (rail + generator electrical)	25.2	71%	Mech power into gen (before rail losses)
Generator rail losses	5.0	95%	Mech power extracted
Generator electrical losses	20.3	75%	Mech power into gen (after rail losses)
Ancillary losses (PE + hotel + Transformer)	7.9	87%	Elec power out of generator


3.4 Oregon (NDBC 46050)

Table 5 – Mean annual power and losses for Oregon (NDBC 46050).


Source data: L2228-N2673 and L2228-N2674

Working folder:Z:\Engineering\LandRAY\Design Files\0000 Design Conditions and Response\LCOE

Power Annual Power [kW]	OR (ndbc46050)
Mechanical power extracted	129.3
Mechanical power into generator (before rail bearing losses)	120.1
Mechanical power into generator (after rail bearing losses)	114.1
Electrical power out of generator	87.9
Electrical power capture (used for TAEP calculation)	78.2



Losses [kW]	OR (ndbc46050)
Fore primary bearing	0.4
Fore secondary bearing	1.2
Fore idler bearing	2.5
Fore seals	0.3
Fore rail bearing	3.3
Fore generator electrical	14.8
Aft primary bearing	0.4
Aft secondary bearing	1.0
Aft idler bearing	2.9
Aft seals	0.3
Aft rail bearing	2.7
Aft generator electrical	11.4
Power electronics	4.4
Hotel loads	3.0
Transformer	2.3



Losses by stage [kW]	OR (ndbc46050)	Efficiency	Efficiency is with respect to...
PTO mechanical losses (prim/sec bearings + idler bearings + seals)	9.2	93%	Mech power extracted
Generator losses (rail + generator electrical)	32.2	73%	Mech power into gen (before rail losses)
Generator rail losses	6.0	95%	Mech power extracted
Generator electrical losses	26.2	77%	Mech power into gen (after rail losses)
Ancillary losses (PE + hotel + Transformer)	9.7	89%	Elec power out of generator


3.5 Ireland (AMETS A)

Table 6 – Mean annual power and losses for Ireland (AMETS A).


Source data: L2228-N2673 and L2228-N2674

Working folder:Z:\Engineering\LandRAY\Design Files\0000 Design Conditions and Response\LCOE

Power Annual Power [kW]	IRL (ametsA)
Mechanical power extracted	182.6
Mechanical power into generator (before rail bearing losses)	169.1
Mechanical power into generator (after rail bearing losses)	161.6
Electrical power out of generator	126.5
Electrical power capture (used for TAEP calculation)	114.0



Losses [kW]	IRL (ametsA)
Fore primary bearing	0.6
Fore secondary bearing	1.5
Fore idler bearing	4.0
Fore seals	0.4
Fore rail bearing	4.0
Fore generator electrical	18.9
Aft primary bearing	0.7
Aft secondary bearing	1.3
Aft idler bearing	4.6
Aft seals	0.3
Aft rail bearing	3.4
Aft generator electrical	16.3
Power electronics	6.3
Hotel loads	3.4
Transformer	2.8



Losses by stage [kW]	IRL (ametsA)	Efficiency	Efficiency is with respect to...
PTO mechanical losses (prim/sec bearings + idler bearings + seals)	13.5	93%	Mech power extracted
Generator losses (rail + generator electrical)	42.6	75%	Mech power into gen (before rail losses)
Generator rail losses	7.4	96%	Mech power extracted
Generator electrical losses	35.1	78%	Mech power into gen (after rail losses)
Ancillary losses (PE + hotel + Transformer)	12.5	90%	Elec power out of generator