

Project: HydroAir PTO
Our Reference: 56OP-2114
Owner: Dresser Rand

Rev. 02

Equipment Dimensions and Weights

Switchgear

	Height (mm)	Width (mm)	Depth (mm)	Weight (LBS)
Basic Dimension	2418	914	2507	~4000
Minimum Clearance				
- Front			94	
- Front door			57	
- Rear			92	
- Rear door			57	
- Side		458		
Top	254			
Minimum Clearance	254	458	300	
Maintenance Clearances			1830	
front			1370	
rear				

Clearance Envelope	2672	1372	6007
--------------------	------	------	------

Transformer

	Height (mm)	Width (mm)	Depth (mm)	Weight (LBS)
Basic Dimension	2438	2286	1425	~5500
Minimum Clearance				
- Front			325	
- Rear			325	
- Side		25		
- Top	458			
Minimum Clearance	458	25	650	
Recommended Clearance				
- Front			458	
- Rear			458	
- Side		458		
- Top	458			
Recommended Clearance	458	458	916	

Clearance Envelope	2896	3202	2341
--------------------	------	------	------

Project: HydroAir PTO
Our Reference: 56OP-2114
Owner: Dresser Rand

Rev. 02

Equipment Dimensions and Weights

Inverter

	Height (mm)	Width (mm)	Depth (mm)	Weight (LBS)
Basic Dimension	2700	4000	600	~5770
- Additional Load Breaker		600		
Minimum Clearance				
- Front			915	
- Front door				
- Rear			25	
- Rear door				
- Side		25		
Top	250			
Minimum Clearance	250	25	940	

Clearance Envelope	2950	4625	1540
--------------------	------	------	------

Braking Resistor

	Height (mm)	Width (mm)	Depth (mm)	Weight (LBS)
Basic Dimension	620	960	1110	~124
Recomended Clearance				
- Front			150	
- Front door				
- Rear			150	
- Rear door				
- Left Side		150		
- Right Side		150		
Top	500			
Recomended Clearance	500	300	300	

Clearance Envelope	1120	1260	1410
--------------------	------	------	------